

1 **Removal and Growth of Microorganisms across Treatment and Simulated Distribution at**
2 **a Pilot-Scale Direct Potable Reuse Facility**

3
4 **Scott E. Miller^{1,2}, Roberto A. Rodriguez³, and Kara L. Nelson^{1,2,*}**

5
6 ¹Department of Civil and Environmental Engineering, College of Engineering, University of
7 California, Berkeley, CA, United States;

8 ²National Science Foundation Engineering Research Center for Re-inventing the Nation's Urban
9 Water Infrastructure, Berkeley, CA, United States;

10 ³School of Public Health, University of Texas Health Sciences Center at Houston, TX, United
11 States

12
13 Corresponding author email: karanelson@berkeley.edu

14
15 **Key words:** advanced water treatment, log removal values, flow cytometry, ATP, assimilable
16 organic carbon, chlorine residual

17

18 **Table of Contents**

19 **1. SUPPLEMENTARY METHODS.....2**

20 1.1. CONVENTIONAL WASTEWATER TREATMENT PLANT2

21 1.2. OVERVIEW OF MAJOR TREATMENT PROCESSES OF THE PILOT TREATMENT FACILITY2

22 1.3. OZONE OPERATION2

23 1.4. MICROFILTRATION AND ULTRAFILTRATION OPERATION3

24 1.5. REVERSE OSMOSIS AND NANOFILTRATION OPERATION3

25 1.6. UV / ADVANCED OXIDATION PROCESS OPERATION3

26 1.7. GRANULAR ACTIVATED CARBON FILTER OPERATION3

27 **2. SUPPLEMENTARY TABLES5**

28 **3. SUPPLEMENTARY FIGURES10**

29 **4. REFERENCES13**

30

31

32

33

34 **1. Supplementary Methods**

35

36 **1.1. Conventional wastewater treatment plant**

37 The Roberto R. Bustamante Wastewater Treatment Plant supplied unchlorinated secondary
38 wastewater effluent to the pilot advanced treatment train. The Bustamante plant is a conventional
39 activated sludge facility with primary clarifiers, aeration basins designed for full nitrification of
40 ammonia, and secondary clarifiers. It should be noted that despite its design, the facility often fails
41 to fully nitrify ammonia during high loading periods.

42

43 **1.2. Overview of major treatment processes of the pilot treatment facility**

44 Unchlorinated secondary wastewater effluent was treated sequentially by the following processes
45 (detailed information on each process is provided in later sections):

46

47 (1) **ozonation**, with a fixed target ozone concentration of 3.5 mg/L, ~5 min of storage time,
48 and no detectable effluent residual. Ozonation was operated from October 26, 2015 –
49 January 9, 2016 to evaluate potential benefits to MF/UF operation (e.g., lower biofouling
50 and longer run-times between membrane backwashing);

51 (2) **chloramination**, with a target concentration of 2 – 4 mg/L as Cl₂, added to reduce
52 biofouling of downstream membranes;

53 (3) **parallel microfiltration (MF)** and **ultrafiltration (UF)** membranes, with nominal pore
54 sizes of 0.1 μm and 0.04 μm, respectively;

55 (4) **parallel** membrane desalination units: one tightly-bound **nanofiltration (NF)**; (Dow, model
56 NF90-400/34i) and one **reverse osmosis (RO)**; (Hydranautics, model ESPA-LD), both
57 operated at an overall permeate recovery of ~80% and each composed of 12 first-stage
58 elements feeding 6 second-stage elements;

59 (5) an **UV-advanced oxidation process (AOP)** consisting of low-pressure UV light (Trojan
60 UV Swift SC B08™) supplied at a dose of 840 mJ/cm² and H₂O₂ dosed to a target
61 concentration of 4 mg/L. The AOP operational setpoints were chosen to target a 1.2-log₁₀
62 reduction of N-nitrosodimethylamine by photolysis and a 0.5-log₁₀ reduction of 1,4-
63 dioxane with advanced oxidation;

64 (6) three **parallel granular activated carbon (GAC)** filters for quenching residual H₂O₂,
65 consisting of a different type of filter media and operated at empty bed contact times of
66 five minutes (GAC 1 and GAC 2) or 15 minutes (GAC 3).

67

68 **1.3. Ozone operation**

69 Ozone was operated during the latter half of the pilot test study to investigate possible
70 benefits of ozonation on operation of downstream membranes (e.g., lower biofouling and longer
71 run times). The ozonation unit was operated from October 26, 2015 to January 9, 2016, except for
72 the dates of November 24 – December 2, 2015. The ozone dose was set as 0.5 mg/L of O₃ per 1
73 mg/L of total organic carbon in the secondary wastewater feed to the pilot, which was measured
74 as ~6 – 8 mg/L. Therefore, the ozone setpoint was set to 3.5 mg/L and was fed at a constant rate.
75 Ozone treatment occurred in a reaction tank (~1 min hydraulic retention time), and effluent water
76 was sent to an ozone decay tank (~4.5 min hydraulic retention time) to ensure no ozone reached
77 the microfiltration or ultrafiltration membranes.

78

79

80 **1.4. Microfiltration and ultrafiltration operation**

81

82 **Table S1:** Microfiltration and ultrafiltration operating and cleaning parameters

Parameter	Microfiltration	Ultrafiltration
Nominal Pore Size	0.01 um	0.04 um
Recovery	95.40%	~94%
Backwash Interval	~22 min	25 min
Maintenance Clean Interval	48 hours	36 hours
Integrity Test Interval	24 hours	24 hours
Maintenance Clean		
Solution	1,250 mg/L NaOCl	200 mg/L NaOCl
Target Residual	600 mg/L NaOCl	NA
Recovery Clean		
Step 1 Solution	1% NaOH + 1,000 ppm NaOCl	~1% citric acid + pH ~2 by HCl
Step 1 Duration	~2 hours	~2 hours
Step 2 Solution	2% citric acid	500 ppm NaOCl
Step 2 Duration	~1 hour	~2 hours

83

84 **1.5. Reverse osmosis and nanofiltration operation**

85 The nanofiltration (NF; Dow, model NF90-400/34i) and reverse osmosis (RO; Hydranautics, model ESPA-LD) membranes were each configured with 12 first-stage elements that fed six second-stage elements. They were operated at a flux of ~12 gallons per square foot per day and an overall permeate recovery of ~80%.

86 To limit mineral scaling, sulfuric acid was added to the RO and NF feed waters to a pH setpoint of 6.5 before November 12 (“Phase 1”) and a pH of 6.1 after November 12 (“Phase 2”). Over the course of Phase 1 the salt passage in the RO increased, indicating damage to the membranes attributable to formation of excessive scale. The second-stage RO elements were replaced on November 11, 2015, which restored salt rejection efficacy before the start of Phase 2.

87

88 **1.6. UV / advanced oxidation process operation**

89 The H₂O₂-based UV-advanced oxidation process (AOP) was designed to reduce 1.2 log₁₀ of NDMA by photolysis and 0.5 log₁₀ of dioxane by advanced oxidation. As part of the pilot testing, the AOP was fed RO permeate between 9/25/15 – 11/18/15 and NF permeate between 11/19/15 – 1/22/16. Arcadis engineers observed no noticeable impact on AOP performance between using RO or NF permeates as feed.

90

91 **1.7. Granular activated carbon filter operation**

92 Three granular activated carbon (GAC) filters were established one week before full operation of the advanced treatment facility. The filter media was catalytic re-agglomerated bituminous GAC (column 1; Calgon Centaur(R) HSL 8x30), catalytic coconut-shell derived GAC (column 2; Evoqua AquaCarb(R) 830), and re-agglomerated bituminous GAC (column 3; Calgon Filtrasorb(R) 300), respectively. Columns 1 and 2 were manufactured with proprietary “catalytic” properties that purportedly increase rates of reaction with oxidants like hydrogen peroxide by

93

109 increasing the number of sites available for catalysis. GAC filters were constructed identically
110 (except for media type) at the pilot site in unsterile conditions. GAC media was installed as six-
111 foot deep media beds loaded into 4-inch diameter clear PVC pipes that were exposed to ambient
112 light.

113 Columns 1 and 2 were operated in catalytic mode at 0.8 gpm, corresponding to a surface
114 loading rate of 9.2 gpm per square foot and an empty bed contact time of 5 minutes. Column 3
115 was operated in adsorption mode at a flow rate of 0.25 gpm, corresponding to a surface loading
116 rate of 2.9 gpm per square foot and an empty bed contact time of 15 minutes. Column 3 was
117 operated in adsorption mode to assess potential benefits of additional total organic carbon removal.
118 The filter columns were backwashed with stored GAC filtrate approximately every 2 – 4 weeks
119 after appreciable increases in head loss.

120

121

122 **2. Supplementary Tables**

123

124 **Table S2:** Summary statistics for the standard error of the mean (i.e., precision of) for primary
 125 measurements for cell counts, ATP, and assimilable organic carbon assays. Sample count (n) is
 126 the number of triplicate measurements taken for each assay across the entire study period.

	WW 2ndary	Ozone	Chloro- mine	MF/UF	MF/UF Storage Tank	NF/RO	NF/RO Storage	AOP	GAC	Reservoir	SDS	Full Scale DWDS
ASSIMILABLE ORGANIC CARBON – Standard Error of the Mean of Primary Measurements (%)												
Average	2	4	4	4	2	17	44	28	14	NA	NA	NA
St. Dev.	1	3	3	3	2	18	33	30	16	NA	NA	NA
Median	2	4	4	3	2	13	43	28	5	NA	NA	NA
Sample Count (n)	10	5	6	18	7	18	7	5	33	2	2	0
TOTAL CELL COUNT – Standard Error of the Mean of Primary Measurements (%)												
Average	2	3	4	23	5	16	7	11	3	40	7	28
St. Dev.	1	3	4	26	4	14	3	9	2	22	7	20
Median	1	2	3	11	4	12	8	8	2	37	5	27
Count	12	12	12	24	12	24	12	12	36	90	90	11
INTACT CELL COUNT – Standard Error of the Mean of Primary Measurements (%)												
Average	2	4	3	28	4	19	15	13	3	66	13	38
St. Dev.	2	4	3	28	3	13	18	7	2	36	16	40
Median	1	2	2	25	4	17	6	14	3	77	7	18
Count	12	12	12	24	12	24	12	12	36	90	90	11
<i>(repeated header for reference)</i>	WW 2ndary	Ozone	Chloro- mine	MF/UF	MF/UF Storage Tank	NF/RO	NF/RO Storage	AOP	GAC	Reservoir	SDS	Full Scale DWDS
TOTAL ATP – Standard Error of the Mean of Primary Measurements (%)												
Average	6	4	3	2	1	2	1	5	3	5	2	NA
St. Dev.	4	3	2	1	1	2	1	3	4	3	2	NA
Median	5	3	3	2	1	1	1	4	2	4	1	NA
Count	8	8	8	16	8	16	8	8	24	15	48	0
INTRACELLULAR ATP – Standard Error of the Mean of Primary Measurements (%)												
Average	16	10	3	3	1	2	2	5	3	4	2	NA
St. Dev.	9	15	4	3	1	2	2	4	2	2	1	NA
Median	13	3	2	2	1	1	1	5	2	4	1	NA
Count	8	8	8	16	8	16	8	8	24	15	48	0

127 **Table S3:** Nutrient and mineral buffers added to samples in the AOC assay to create carbon-
 128 limiting conditions, per protocol in Drinking Water Microbiology Group at Eawag, Switzerland
 129 (Hammes, 2015).

(1) Phosphate-Nitrogen Buffer	Concentration (g/L)
Sodium phosphate dibasic	1.28
Potassium phosphate monobasic	0.3
Ammonium sulfate	1.77
(2) Iron-Chloride Solution (10 mM)	
Iron (III) chloride hexahydrate	2.7
(3) Trace Element Solution	
Calcium carbonate	8
Magnesium chloride	1.15
Copper sulfate	0.15
Cobalt chloride	0.13
Zinc oxide	0.4
Boric acid	0.12
Magnesium chloride	13.42
Sodium molybdenum	1.04

130
 131 **Table S4: Determination of the lower limit of quantification of flow cytometric total and**
 132 **intact cell counts.** All samples were 0.1 µm-filtered bottled mineral water (Evian, France) run
 133 with 1,000 uL of volume on a BD Accuri™ C6 flow cytometer.

Sample Blank w/o Fluorescent Dye		Total Cell Counts Assay		Intact Cell Counts Assay	
Replicate #	Count [cells/mL]	Replicate #	cells/mL	Replicate #	cells/mL
1	0	1	5	1	6
2	0	2	2	2	13
3	0	3	3	3	6
4	0	4	3	4	5
5	0	5	5	5	10
6	0	6	2	6	3
7		7	9	7	6
8		8	1	8	18
9		9	3	9	3
10		10	8	10	8
11		11	1	11	4
Average	0	Average	3.8	Average	7.5
Standard Deviation	0.0	Standard Deviation	2.6	Standard Deviation	4.7
		3x Standard Deviation	7.9	3x Standard Deviation	14.1
		Limit of Quantification	11.7	Limit of Quantification	21.6

134
 135
 136

137 **Table S5: Summary statistics for total and intact cell count measurements across the pilot**
 138 **treatment train.** For calculation of average and standard deviation, all samples with cell counts
 139 below the limit of quantification (“LoQ”) were set to the LoQ.

Grouped Sampling Location	Flow Cytometry Assay	Avg. (cells/mL)	St. Dev. (cells/mL)	Count (n)	Count (n) less than LoQ	% Less than LoQ
WW 2ndary	Total Cell Count	1.68E+07	1.93E+07	10	0	0
WW 2ndary	Intact Cell Count	1.30E+07	1.56E+07	10	0	0
Ozone	Total Cell Count	1.44E+07	1.92E+07	8	0	0
Ozone	Intact Cell Count	6.62E+06	1.24E+07	8	0	0
Chloramine	Total Cell Count	1.23E+07	1.62E+07	10	0	0
Chloramine	Intact Cell Count	5.11E+06	8.15E+06	10	0	0
MF/UF	Total Cell Count	6.91E+02	1.21E+03	17	0	0
MF/UF	Intact Cell Count	4.49E+02	9.61E+02	17	4	24
MF/UF Tank	Total Cell Count	3.15E+03	1.82E+03	8	0	0
MF/UF Tank	Intact Cell Count	2.31E+03	1.42E+03	8	0	0
NF/RO	Total Cell Count	7.40E+01	8.70E+01	24	0	0
NF/RO	Intact Cell Count	3.34E+01	2.69E+01	24	17	71
NF/RO Tank	Total Cell Count	6.50E+02	9.57E+02	9	0	0
NF/RO Tank	Intact Cell Count	3.74E+02	6.36E+02	9	4	44
AOP	Total Cell Count	4.66E+02	6.47E+02	7	0	0
AOP	Intact Cell Count	1.65E+02	1.96E+02	7	0	0
GAC	Total Cell Count	1.08E+04	4.62E+03	33	0	0
GAC	Intact Cell Count	7.88E+03	3.28E+03	33	0	0
Reservoir	Total Cell Count	5.35E+01	4.69E+01	30	1	3
Reservoir	Intact Cell Count	2.50E+01	8.73E+00	30	24	80
SDS	Total Cell Count	1.27E+04	2.07E+04	88	0	0
SDS	Intact Cell Count	3.70E+03	9.76E+03	88	2	2

140
 141
 142

143 **Table S6: Summary statistics for total and intracellular ATP measurements across the pilot**
 144 **treatment train.** For calculation of average and standard deviation, all samples with cell counts
 145 below the limit of quantification (“LoQ”) were set to the LoQ.


Grouped Sampling Location	ATP Assay	Avg. (cells/mL)	St. Dev. (cells/mL)	Count (n)	Count (n) less than LoQ	% Less than LoQ
WW 2ndary	Total ATP	5.88E+00	2.69E+00	8	0	0
WW 2ndary	Intracellular ATP	5.14E+00	2.51E+00	8	0	0
Ozone	Total ATP	3.83E+00	2.02E+00	8	0	0
Ozone	Intracellular ATP	1.26E+00	8.71E-01	8	0	0
Chloramine	Total ATP	4.19E+00	2.52E+00	8	0	0
Chloramine	Intracellular ATP	8.16E-01	6.94E-01	8	0	0
MF/UF	Total ATP	2.63E+00	1.35E+00	16	0	0
MF/UF	Intracellular ATP	2.22E-01	3.69E-01	16	0	0
MF/UF Tank	Total ATP	2.80E+00	1.38E+00	8	0	0
MF/UF Tank	Intracellular ATP	1.50E-01	1.02E-01	8	0	0
NF/RO	Total ATP	5.44E-03	5.17E-03	16	0	0
NF/RO	Intracellular ATP	2.12E-04	2.55E-04	16	1	6
NF/RO Tank	Total ATP	4.72E-03	2.29E-03	8	0	0
NF/RO Tank	Intracellular ATP	1.95E-04	1.59E-04	8	1	13
AOP	Total ATP	2.08E-04	8.20E-05	8	0	0
AOP	Intracellular ATP	5.37E-05	6.75E-05	8	2	25
GAC	Total ATP	2.48E-03	1.18E-03	21	0	0
GAC	Intracellular ATP	1.08E-03	9.22E-04	21	0	0
Reservoir	Total ATP	4.95E-04	1.91E-04	15	0	0
Reservoir	Intracellular ATP	-7.08E-05	2.25E-04	15	6	40
SDS	Total ATP	1.06E-02	1.45E-02	48	0	0
SDS	Intracellular ATP	1.13E-03	1.51E-03	48	2	4

146


147 **Table S7: AOC concentrations after major treatment processes in the pilot facility.** AOC
 148 concentrations (in µg/L) averaged from all sampling dates are shown followed by standard
 149 deviations from technical triplicate measurements in parentheses. Sample count (n) is shown to
 150 the right of each data subset. Data for individual treatment processes and combined parallel
 151 processes are shown on separate rows (e.g., “MF/UF”). Data on the right half of columns show
 152 MF and UF data collected at 9 hours or more after a maintenance clean or recovery clean.

Sample Location	All Samples						MF and UF Samples Collected 9+ hours After Cleaning					
	All Days	(n)	Ozone "On"	(n)	Ozone "Off"	(n)	All Days	(n)	Ozone "On"	(n)	Ozone "Off"	(n)
Secondary Wastewater Feed	335 (103)	10	333 (79)	6	338 (146)	4						
Ozone	790 (500)	6	790 (500)	6	NA	NA						
Chloramine	465 (299)	6	943 (NA)	1	440 (213)	5						
MF	398 (207)	8	414 (164)	4	380 (269)	4	303 (195)	6	443 (188)	3	162 (28)	3
UF	260 (157)	10	258 (105)	5	260 (197)	5	203 (95)	6	232 (101)	4	146 (64)	2
MF + UF ("MF/UF")	320 (185)	18	327 (150)	9	312 (225)	9	253 (155)	12	323 (172)	7	156 (39)	5
MF/UF Storage Tank	345 (170)	6	373 (0.35)	2	330 (218)	4						
RO	0 (0)	8	0 (0)	3	0 (0)	5						
NF	0 (0)	8	0 (0)	3	0 (0)	5						
NF + RO ("NF/RO")	0 (0)	16	0 (0)	7	0 (0)	9						
NF/RO Storage Tank	0 (0)	6	0 (0)	2	0 (0)	4						
AOP	0 (0)	6	0 (0)	2	0 (0)	4						
GAC 1	67 (55)	6	154 (NA)	1	50 (39)	5						
GAC 2	66 (35)	6	64 (NA)	1	67 (39)	5						
GAC 3	47 (26)	6	21 (NA)	1	52 (27)	5						


155 3. Supplementary Figures
156




157
158 **Figure S1: Adjusted gates for flow cytometry on the BD Accuri C6 for microfiltration,**
159 **ultrafiltration, nanofiltration, reverse osmosis, and UV-advanced oxidation.** The top two and
160 bottom two pictures show cell counts for 0.1 μm -filtered nanopure water (“MQ 0.1f SG 1”) and
161 reverse osmosis permeate (“13 SGPI 1”), respectively. The gate applied in the left-hand column is
162 a publicly available gate developed by researchers at the Swiss Federal Institute of Aquatic Science
163 and Technology (“Eawag, Switzerland) for aquatic samples analyzed on the BD Accuri™ C6 flow
164 cytometer (Gatza, Hammes, & Prest, 2013), whereas the gate applied in the right-hand column is
165 modified from the Eawag template to avoid excessive noise in low-cell count samples.
166
167




169
 170 **Figure S2: Calibration curve for determining ATP concentrations.** This calibration curve was
 171 created by diluting pure ATP standard diluted in 0.1- μ m filtered and autoclaved ultrapure water.
 172 The curve was experimentally determined to be $y = 2,808,903 * x + 410267$, where “y” is
 173 luminescence in RLU and “x” is ATP concentration in nM. Error bars show the standard deviation
 174 of triplicate measurements. The curve was found to be linear between ATP concentrations of 10^{-4}
 175 and 10^2 nM with an R^2 of 0.9998.
 176



177
 178 **Figure S3: Assimilable organic carbon calibration curve based on net growth of total flow**
 179 **cytometric cell counts on known concentrations of acetate-carbon.** Samples were performed
 180 in triplicate. Standard deviation of each sample is shown by vertical bars.



181
 182 **Figure S4: Time series of the reservoir and SDS free chlorine concentrations, and SDS total**
 183 **and intact cell counts.** All free chlorine and cell count data represent averages of the three
 184 simulated distribution systems for that day. Cell count measurements were conducted in technical
 185 triplicate.
 186



187 Sampling Location ⊖ SDS 1 ⊖ SDS 2 ⊖ SDS 3
 188 **Figure S5: Relationship of intact cell counts and intracellular ATP in the SDS.** A linear
 189 correlation was found ($R^2 = 0.47$; $p < 0.001$; $n = 43$), and an average ATP-per-cell value of $6.87 \pm$
 190 7.72×10^{-10} nmol/cell was calculated from the dataset. All measurements were conducted in
 191 technical triplicate.

192 **4. References**

193 Gatza, E., Hammes, F., & Prest, E. (2013). *Assessing Water Quality with the BD Accuri™ C6*
194 *Flow Cytometer* (pp. 1–12).

195 Hammes, F. (2015, February 18). Assimilable Organic Carbon (AOC): Filtration Method.
196 Zurich, Switzerland.